


Computer controlled systems

Lecture 7, March 31, 2017

version: 2018.11.27. – 12:39:05

Exercises

We consider a simple pendulum mounted on a cart that can move horizontally:



- M is the mass of the cart
- m is the mass of the pendulum
- $2l$ is the length of the pendulum
- l is the distance of the pivot point from the pendulum's center of mass
- F is an external force (input) acting on the cart
- b is the damping factor
- r is the (horizontal) position of the cart
- $\dot{r} = v$ is the (horizontal) velocity of the cart
- φ is the angle of the cart (clockwise direction)
- $\dot{\varphi} = \omega$ is the angular velocity of the cart (clockwise direction)
- $\varphi = 0$ **unstable equilibrium point:** if the pendulum's center of mass is exactly **above** its pivot point (is vertical and pointing towards the sky)
- $\varphi = \pi$ **stable equilibrium point:** if the pendulum's center of mass is exactly **below** its pivot point

This system has a nonlinear equation, which can be linearized in a certain operating point¹ (see Appendix). The state vector of the system is the following: $x = (r \ v \ \varphi \ \omega)^T$, furthermore, the external force F constitutes the input of the system (u). The nonlinear model of the system is: $\dot{x} = f(x) + g(x)u$, where

$$f(x) = \begin{pmatrix} v \\ \frac{1}{q} (4ml \sin(\varphi)\omega^2 - 1.5mg \sin(2\varphi) - 4bv) \\ \omega \\ \frac{3}{lq} \left(-\frac{ml}{2} \sin(2\varphi)\omega^2 + (M+m)g \sin(\varphi) + b \cos(\varphi)v \right) \end{pmatrix}, \quad g(x) = \frac{1}{lq} \begin{pmatrix} 0 \\ 4l \\ 0 \\ -3 \cos(\varphi) \end{pmatrix} \quad (1)$$

where $q = 4(M+m) - 3m \cos(\varphi)^2$. For the full derivation see Appendix. For each exercise, you can use your own parameter configuration. Some examples are listed below.

<p>(A) no friction</p> <p>$M = 0.5$ [kg]</p> <p>$m = 0.2$ [kg]</p> <p>$l = 1$ [m]</p> <p>$g = 9.8$ [m/s²]</p> <p>$b = 0$ [kg/s]</p>	<p>(B) with friction</p> <p>$M = 0.5$ [kg]</p> <p>$m = 0.2$ [kg]</p> <p>$l = 1$ [m]</p> <p>$g = 9.8$ [m/s²]</p> <p>$b = 10$ [kg/s]</p>	<p>(C) with friction + heavy rod</p> <p>$M = 0.5$ [kg]</p> <p>$m = 10$ [kg]</p> <p>$l = 1$ [m]</p> <p>$g = 9.8$ [m/s²]</p> <p>$b = 10$ [kg/s]</p>
--	---	--

¹munkapont

1. Linearized model around the *stable* equilibrium point ($\varphi = \pi$)

Linearized model around the operating point $x^* = (0 \ 0 \ \pi \ 0)^T$:

$$A = \begin{pmatrix} 0 & 1 & 0 & 0 \\ 0 & -\frac{4b}{4M+m} & -\frac{3mg}{4M+m} & 0 \\ 0 & 0 & 0 & 1 \\ 0 & -\frac{3b}{l(4M+m)} & -\frac{3(M+m)g}{l(4M+m)} & 0 \end{pmatrix}, \quad B = \frac{1}{l(4M+m)} \begin{pmatrix} 0 \\ 4l \\ 0 \\ 3 \end{pmatrix}, \quad C = \begin{pmatrix} 1 & 0 & 0 & 0 \\ 0 & 0 & 1 & 0 \end{pmatrix} \quad (2)$$

(**ss,tf**) 1. Determine the system's transfer function:

$$H(s) = \begin{pmatrix} H_{u \rightarrow r}(s) \\ H_{u \rightarrow \varphi}(s) \end{pmatrix} \quad (3)$$

(**impulse**) 2. Determine the impulse response of the system

(**step**) 3. Determine the step response of the system for both $H_{u \rightarrow r}(s)$ and $H_{u \rightarrow \varphi}(s)$. Determine the DC gain of the system.

(**eig**) 4. Determine the poles of the system. Is the linearized model locally/globally/asymptotically stable? What can we say about the original nonlinear system's stability? How does the stability properties change if we assume friction?

(**bodeplot**) 5. Determine the Bode plot of the transfer function $H_{u \rightarrow \varphi}(s)$. Set the frequency unit to be in Hz. Determine the own (or resonance) frequency (f_r) of the system.

(**nyquist**) 6. Plot the Nyquist diagram of $H_{u \rightarrow \varphi}(s)$.

(**lsim**) 7. Plot the output of the system if the input is $u_i(t) = A_i \sin(2\pi f_i t)$, where

$$(a) \ f_2 = f_r \ [Hz], \ A_2 = 1 \ [N] \quad (b) \ f_3 = 4 \ [Hz], \ A_3 = 20 \ [N] \quad (c) \ f_1 = 0.1 \ [Hz], \ A_1 = 1 \ [N]$$

Considering the Bode diagram, what is expected to happen in each cases? In certain cases, we shall notice that the system's motion is quite unusual, why?

(**ode45**) 8. Solve the linearized differential equation $\dot{x} = Ax + Bu$ with different initial conditions. The input may be zero first, than you can use the values from the previous example.

(**ctrb**) 9. Is the linearized model controllable?

(**obsv**) 10. Is the linearized model observable? How does this change if we measure only the angle of the rod φ .

(**null**) (a) Compute the kernel (null space) of \mathcal{O}_4 .

(**orth**) (b) Give the bases of the image space of \mathcal{O}_4 .

(c) Give the matrix T of the linear state transformation, which produces the observability staircase representation:

$$\begin{pmatrix} \dot{\bar{x}}_1 \\ \dot{\bar{x}}_2 \end{pmatrix} = \begin{pmatrix} A_o & 0 \\ A_{21} & A_{\bar{o}} \end{pmatrix} \begin{pmatrix} \bar{x}_1 \\ \bar{x}_2 \end{pmatrix} + \begin{pmatrix} B_o \\ B_{\bar{o}} \end{pmatrix} u$$

$$y = (C_o \ 0) \begin{pmatrix} \bar{x}_1 \\ \bar{x}_2 \end{pmatrix}$$

2. Nonlinear system simulation

11. Solve the nonlinear ODE (1) numerically, use the **ode45** solver:

$$(a) \ x_0 = (0 \ 0 \ \frac{5\pi}{6} \ 0)^T, \ u(t) = 0$$

$$(b) \ x_0 = (0 \ 0 \ \frac{\pi}{6} \ 0)^T, \ u(t) = 0$$

$$(c) \ x_0 = 0, \ u(t) = \sin(2\pi f_r t)$$

(d) You can play with x_0 and $u(t)$ as you want


3. PID controller design

12. Consider the following SISO model given by the transfer function:

$$G(s) = \frac{s^2 + 3s + 2}{s^3 + 2s^2 - 6s + 8} \quad (4)$$

(pzmap) (a) Determine the poles and the zeros of the system. Is the system minimum-phase?

(pidTuner) (b) Design a PID controller $C(s)$ which provides stability and reference tracking.



$$C(s) = K_p + \frac{K_i}{s} + K_d s = \frac{K_d s^2 + K_p s + K_i}{s} \quad (5)$$

Appendix

I. Linearize a nonlinear model around an equilibrium point

We have a nonlinear system in the following form:

$$\dot{x} = F(x, u) = f(x) + g(x)u \quad (6)$$

Let $x^* \in \mathbb{R}^n$ be an equilibrium point of the nonlinear system, which means that $F(x^*, 0) = f(x^*) = 0$. We assume that the system operates around this equilibrium point, and by default there is no input given to the system. Therefore, we say that the system's operating point² is $(x^*, u^* = 0)$.

The Jacobian matrix of $F(x, u)$ is

$$D[F(x, u)] = \left(\frac{\partial F(x, u)}{\partial x} \mid \frac{\partial F(x, u)}{\partial u} \right) = \left(\frac{\partial f(x)}{\partial x} + \frac{\partial g(x)}{\partial x} u \mid g(x) \right) \quad (7)$$

The value of the Jacobian matrix in this operating point is

$$D[F(x^*, 0)] = \left(\frac{\partial f(x^*)}{\partial x} \mid g(x^*) \right) \quad (8)$$

Now we estimate $F(x, u)$ by its first order Taylor polynomial around the operating point:

$$\begin{aligned} F(x, u) &\simeq \underbrace{F(x^*, 0)}_0 + D[F(x^*, 0)] \begin{pmatrix} x - x^* \\ u - 0 \end{pmatrix} \\ F(x, u) &\simeq \frac{\partial f(x^*)}{\partial x} (x - x^*) + g(x^*)u \end{aligned} \quad (9)$$

Hence, the linear model is

$$\dot{x} = A(x - x^*) + Bu, \quad \text{where} \quad \begin{aligned} A &:= \frac{\partial f(x^*)}{\partial x} \\ B &:= g(x^*) \end{aligned} \quad (10)$$

There's only one more thing left, we need to center the system. We introduce the centered state vector $\bar{x} := x - x^*$. Therefore, the time derivative of the transformed state vector will be:

$$\dot{\bar{x}} = \dot{x} = A(x - x^*) + Bu = A\bar{x} + Bu \quad (11)$$

Finally, we obtained the centered linearized model:

$$\dot{\bar{x}} = A\bar{x} + Bu, \quad \text{where} \quad \begin{aligned} A &:= \frac{\partial f(x^*)}{\partial x} \\ B &:= g(x^*) \end{aligned} \quad (12)$$

²munkapont

II. Derivation of the inverted pendulum's equation

The equation of the inverted pendulum is the following:

$$\begin{aligned} (M+m)\ddot{x} + ml\ddot{\varphi}\cos(\varphi) - ml\dot{\varphi}^2\sin(\varphi) &= F \\ ml\ddot{x}\cos(\varphi) + \frac{4}{3}ml^2\ddot{\varphi} - mgl\sin(\varphi) &= 0 \end{aligned} \quad (13)$$

The nonlinear state space equation of the inverted pendulum:

$$\begin{cases} \dot{x} = v \\ \dot{v} = \frac{1}{q}(4ml\sin(\varphi)\omega^2 - 1.5mg\sin(2\varphi) - 4bv) + \frac{4}{q}F \\ \dot{\varphi} = \omega \\ \dot{\omega} = \frac{3}{lq}\left(-\frac{ml}{2}\sin(2\varphi)\omega^2 + (M+m)g\sin(\varphi) + b\cos(\varphi)v\right) - \frac{3\cos(\varphi)}{lq}F \end{cases} \quad (14)$$

where $q = 4(M+m) - 3m\cos(\varphi)^2$. Let the state vector be $x = (x \ v \ \varphi \ \omega)^T$.

$$f(x) = \begin{pmatrix} v \\ \frac{1}{q}(4ml\sin(\varphi)\omega^2 - 1.5mg\sin(2\varphi) - 4bv) \\ \omega \\ \frac{3}{lq}\left(-\frac{ml}{2}\sin(2\varphi)\omega^2 + (M+m)g\sin(\varphi) + b\cos(\varphi)v\right) \end{pmatrix}, \quad g(x) = \frac{1}{lq} \begin{pmatrix} 0 \\ 4l \\ 0 \\ -3\cos(\varphi) \end{pmatrix} \quad (15)$$


Linearized model around the stable operating point $x^* = (0 \ 0 \ \pi \ 0)^T$:

$$A = \begin{pmatrix} 0 & 1 & 0 & 0 \\ 0 & -\frac{4b}{4M+m} & -\frac{3mg}{4M+m} & 0 \\ 0 & 0 & 0 & 1 \\ 0 & -\frac{3b}{l(4M+m)} & -\frac{3(M+m)g}{l(4M+m)} & 0 \end{pmatrix}, \quad B = \frac{1}{l(4M+m)} \begin{pmatrix} 0 \\ 4l \\ 0 \\ 3 \end{pmatrix}, \quad C = \begin{pmatrix} 1 & 0 & 0 & 0 \\ 0 & 0 & 1 & 0 \end{pmatrix} \quad (16)$$

Linearized state space model around the unstable operating point $x^* = (0 \ 0 \ 0 \ 0)^T$ is:

$$A = \begin{pmatrix} 0 & 1 & 0 & 0 \\ 0 & -\frac{4b}{4M+m} & -\frac{3mg}{4M+m} & 0 \\ 0 & 0 & 0 & 1 \\ 0 & \frac{3b}{l(4M+m)} & \frac{3(M+m)g}{l(4M+m)} & 0 \end{pmatrix}, \quad B = \frac{1}{l(4M+m)} \begin{pmatrix} 0 \\ 4l \\ 0 \\ -3 \end{pmatrix}, \quad C = \begin{pmatrix} 1 & 0 & 0 & 0 \\ 0 & 0 & 1 & 0 \end{pmatrix} \quad (17)$$

III. A simple control loop (SISO)



- r reference input
- d input disturbance (eg. wind, noise, fault of the actuator, etc.)
- u control input computed by the controller $C(s)$
- y output of system $G(s)$
- e error: difference between the reference input r and the output y

We derive, how the reference input r and the input disturbance d influence the output of $G(s)$:

$$\begin{aligned} y &= G(s)(u+d) = G(s)(u+C(s)(r-y)) \\ &= G(s)d + G(s)C(s)r - G(s)C(s)y \end{aligned} \quad (18)$$

$$\boxed{y = \frac{G(s)}{1+G(s)C(s)}d + \frac{G(s)C(s)}{1+G(s)C(s)}r}$$

In general an actuator³ has a limited power, and it cannot perform arbitrarily large control input u . Therefore, during the controller design, we need to consider what would be the actual control input (u) determined by the controller $C(s)$. From the closed loop system, we can derive the transfer function

³eg. in case of the inverted pendulum the actuator could be the DC motor of cart

describing the influence of r and d on the control input u :

$$\begin{aligned}u &= C(s)(r - y) = C(s)(r - G(s)(d + u)) \\ &= C(s)r - C(s)G(s)d - C(s)G(s)u\end{aligned}$$

(19)

$$u = \frac{C(s)}{1 + G(s)C(s)}r + \frac{-G(s)C(s)}{1 + G(s)C(s)}d$$